


AUGUST 1992

# INSTRUCTIONS FOR THE 1600 SERIES MICROPROCESSOR BASED TEMPERATURE / PROCESS CONTROL



If all else fails,  
please read these  
instructions



**CONTROLS CORPORATION**

• *Dwyer*, Instruments Company

1475 S WHEELING ROAD • WHEELING ILLINOIS 80090 • (708)541-3232

FAX (708)541-7388 • TELEX 297116 LOVE UR

949-1239-1

## TABLE OF CONTENTS

GETTING STARTED .....	2
HOW TO USE THIS BOOK .....	2
DIMENSIONS .....	3
INSTALLATION .....	3
LOGIC JUMPER SELECTION .....	4
INPUT SELECTION .....	4
WIRING .....	5
FRONT PANEL KEY FUNCTIONS .....	6
METHOD FOR SET UP OF A HEAT / COOL CONTROL .....	6
MENU SELECTIONS .....	7
PRIMARY MENU .....	7
SECONDARY MENU .....	8
SECURE MENU .....	11
DIAGNOSTIC ERROR MESSAGES .....	15
CONFIGURATION MENU .....	17
CONFIGURATION CHART .....	18
SPECIFICATIONS .....	20

## GETTING STARTED

1. Install the control as described on page 3.
2. Make sure that the Input DIP switch is set correctly for the Input you wish to use. Instructions on page 3.
3. If you wish to use the Logic (5 VDC) output, make sure that the Logic Jumper is in the correct position. See page 4 for details.
4. Wire your control following the drawing on page 5.
5. Make any programming changes necessary in the Secure (page 11) and Secondary (page 8) Menus. DO NOT make changes to the Configuration Menu unless specifically instructed. If you need to back up in a menu, press the INDEX and DOWN ARROW keys together.
6. To quickly return to the HOME position, press the UP ARROW and ENTER keys together, and then the INDEX and DOWN ARROW keys.

## HOW TO USE THIS BOOK

Because of the number of features available in this control, information is included that may not apply to your specific control. Options, for example, are included in this book, but may not be included in your control. To increase clarity the following conventions are used:


1. Optional features or functions are shown in this book in *Roman type*. The Option code (from the configuration menu) is listed after the menu item in parenthesis. If you do not have an option installed, you may skip any items listed in *Roman type*.

2. The "#" symbol is used in two ways. It is used inside a group of characters to indicate which set point function (SP1 or SP2) is being affected. It is also used before a group of characters of a menu item to indicate that there may be more than one selection or value for that menu item. This is only used when the 4-stage set point option is used (948).

## INSTALLATION


Mount the instrument in a location that will not be subject to excessive temperature, shock, or vibration. All models are designed for mounting in an enclosed panel.

Select the position desired for the instrument on the panel. If more than one instrument is required, only two units can be mounted closely together, either one above the other or side by side. When mounted together, the mounting collar will require modification by removing the inside tab from each collar.




Prepare the panel by cutting and deburring the required opening.

From the front of the panel, slide the housing through the cut out. The housing gasket should be against the housing flange before installing.



ALL TOLERANCES ARE  
-0.00 +0.25mm (-0.000 +0.010)


From the rear of the panel slide the mounting collar over the housing. Hold the housing with one hand and using the other hand, push the collar evenly against the panel until the spring loops are slightly compressed. The ratchets will hold the mounting collar and housing in place.



MOUNTING COLLAR (SHOWN IN POSITION)  
SLIDE COLLAR ONTO THE HOUSING  
BEFORE WIRING THE REAR TERMINALS

## DIMENSIONS

(ALL DIMENSIONS IN MM WITH INCHES IN PARENTHESIS)



PANEL CUTOUT FOR ALL MODELS 45 MM X 45 MM (1.775" X 1.775")  
ALLOW FOR 13 MM (0.5") CLEARANCE AT THE REAR OF INSTRUMENT.  
\* PRESENT FOR ALL OUTPUTS OTHER THAN RELAY.




## LOGIC JUMPER SELECTION

Instruments with SSR or RELAY type outputs can be changed to and from a LOGIC output in the field.



**CAUTION:** Damage to the Instrument may result from an incorrectly installed jumper strip. Follow the instructions carefully.


1. Remove the instrument from its housing. Grasp the front bezel sides and pull forward to release it from the housing lock.
2. Locate the desired logic jumper strip on the left printed circuit board. The **OUTPUT A** jumper strip is always located near the top edge.
3. To remove the logic jumper strip, carefully insert a small flat blade screwdriver between the retaining clip and the jumper at one end of the jumper strip. Apply slight pressure to move the clip away from the jumper end until it is released, then lift it up and out of the clip.
4. To re-install the jumper strip, hold it with the spring contacts in the desired position. Face springs up for **SSR or RELAY** outputs, or face springs down for **LOGIC** outputs. Insert one end of the jumper strip under the retaining clip and press the other end down until the remaining clip engages the jumper.
5. To avoid any damage, recheck the jumper installation and the housing rear terminal panel output wiring.
6. Replace the instrument into its housing.




## INPUT SELECTION

To change the input type, remove the instrument from its housing. Grasp the front bezel sides and pull forward to release it from the housing lock. Locate the dip switch on the right pcb. Determine the input type desired and change the dip switch setting as shown below.


After changing input selection with the DIP switches, be sure to change the InP menu item (page 11) in the Secure Menu.



## WIRING



## FRONT PANEL KEY FUNCTIONS



- INDEX:** Pressing the INDEX key advances the display to the next menu item. May also be used in conjunction with other keys as noted below.
- UP ARROW:** Increments a value, changes a menu item, or selects the item to ON in the upper display.
- DOWN ARROW:** Decrements a value, changes a menu item, or selects the item to OFF in the upper display.
- ENTER:** Pressing ENTER stores the value or the item changed. If not pressed, the previously stored value or item will be retained.
- UP ARROW & ENTER:** Pressing these keys simultaneously brings up the **secondary menu** starting at the auto/manual selection. Pressing these keys for 5 seconds will bring up the **secure menu**.
- INDEX & DOWN ARROW:** Pressing these keys simultaneously will allow backing up one menu item, or if at the first menu item they will cause the display to return to the **primary menu**. If an alarm condition has occurred, these keys may be used to reset the alarm.
- INDEX & ENTER:** Pressing these keys simultaneously and holding them for 5 seconds allows recovery from the various error messages. The following menu items will be reset:

**LPbr:** Loop break  
**ALIH:** Alarm inhibit  
**bAd InP:** Bad input error message  
**CHEC CAL:** Check calibration error message  
**SEnC:** Sensor rate of change  
**OPEn InP:** Open input error message  
**ArEA:** Area error message

Correct the problems associated with the above conditions first before using these reset keys. More than one error could be present. Caution is advised since several items are reset at one time.

While in the **Primary** or **Secondary** menu, if no key is pressed for a period of 30 seconds, the display will return to the **HOME** position displaying the PV and SV values. The time is increased to 1 minute when in the **Secure** menu.

**NOTE:** To move to the **primary menu** quickly from any other menu, press the **UP ARROW & ENTER** keys followed by pressing the **INDEX & DOWN ARROW** keys.

## METHOD FOR SET UP OF A HEAT / COOL CONTROL WITH SELF TUNE

Determine if the process is predominantly heating or cooling. An extruder, for example, is predominantly cooling when running product. An environmental chamber can be either heating or cooling. (For explanation of terms see pages 12 & 13.)

If the process is predominantly cooling, set S1St to dlr and S2St to rE. If the process is predominantly heating, set S1St to rE and S2St to dlr. Redirect SP1 to output A or B as required by the hardware (see SP1o). Set S2t to dE. Set SP2 for zero (no overlap of bands, no deadband). Set Pb2 to a desired value (default is 12° F). Set tunE to SELF, Strt to YES, and LErn to End.

Start the process and wait for it to come to stability. Occasionally check that the Self Tune has completed the learning process by INDEXing to Strt in the secondary menu. If the YES value has changed to no, then the process has been learned. Once learning is complete, you may adjust SP2 to either overlap the SP1 band (SP2 value less than zero), or add some separation between them (deadband -- SP2 greater than zero) if required to optimize control.

## SECURITY LEVEL SELECTION

Four levels of security are provided. The display shows the current security level. To change security levels change the password value using the **UP & DOWN ARROW** keys and pressing the **ENTER** key. Refer to the password table below for the correct value to enter for the security level desired. The SEC menu item security level may be viewed or changed at any time regardless of the present security level. The password values shown in the table cannot be altered, so retain a copy of this page for future reference. This will be the only reference made to password values in this instruction book.

PASSWORD TABLE

SECURITY LEVEL MENU	SECURITY	DISPLAYED VALUE WHEN VIEWED	PASSWORD VALUE TO ENTER
Primary Secondary Secure	Locked Locked Locked	1	1110
Primary Secondary Secure	Unlocked Locked Locked	2	1101
Primary Secondary Secure	Unlocked Unlocked Locked	3	1011
Primary Secondary Secure	Unlocked Unlocked Unlocked	4	111

## MENU SELECTIONS

### PRIMARY MENU

Press **INDEX** to scan the Lower Display. Press **UP ARROW** or **DOWN ARROW** to change the value in the upper display.

In the following the symbol "\*" will be used before a letter to indicate the set point value to be viewed and/or modified. (Applies to Option 948 only.)

**\*SP1** (948) or  
**SP1** Set Point 1, Main Control Point.

**SP2** Set Point 2, if equipped.



## SECONDARY MENU

Hold **UP ARROW & ENTER**. Press **INDEX** to scan the Lower Display. Press **UP ARROW** or **DOWN ARROW** to change the value in the upper display.

**Auto** Auto/Manual Control: Select On or OFF.

**On** Automatic Control

**OFF** Manual Control is enabled. The lower display in the HOME position will display the output in percent for SP1 or SP2, and is adjustable for each from 0.0 to 100 percent. SP1 appears first with a flashing "o" on the right hand corner of the lower display to represent percent. Press **INDEX** to display SP2 output. A flashing "d" will appear on the right hand corner of the lower display to represent percent. When Manual is enabled, the present control outputs are held (bumpless transfer) and displayed. The output for SP1 or SP2 can then be manually adjusted while displayed by pressing the **UP** or **DOWN ARROW** key to change the value, and then the **ENTER** key. The Upper display will normally indicate the Process Value. Since Manual will override most fault messages the upper display could indicate a fault message. Refer to the Diagnostic Error Message Section for further explanation.

**ALLo** Alarm Low: The Low Alarm point is usually set below the Main Set Pt.

**ALHi** Alarm High: The High Alarm Point is usually set above the Main Set Pt.

**SP** Active set point (948): Select **1SP1**, **2SP1**, **3SP1**, or **4SP1**. Allows setting of the multiple stages of SP1, and SP1 tuning constants.

**#SP1** Set Point Value # (948): Select desired value.

**#tun** (948) or

**tunE** Tuning Choice: Select **SELF**, **PId**, **SLO**, **nor**, or **FAST**.

**SELF** The Controller will evaluate the Process and select the PID values to maintain good control. Active for SP1 only.

**Strt** Select YES or no

**YES** Start Learning the Process. After the process has been learned the menu item will revert to no.

**no** Learning will stay in present mode.

**LErn** Select Cont or End

**Cont** Continuously adjust the PID values to maintain the best control. The Process is being monitored at all times by collecting and analyzing the data to adjust the PID values. (adaptive control).

**End** The Process data is collected once and then the PID values are saved, tuning is stopped.

**dFAC** Damping factor, Select **OFF**, 1 to 7. Sets the ratio of Rate to Reset for the **SELF tunE** mode. 7 = most Rate. Factory set to 3. For a fast response process the value should be lowered (less Rate). For a slower process the value should be increased (more Rate).

**PId** Manually adjust the PID values. PID control consists of three basic parameters, Proportional Band (Gain), Reset Time (Integral), and Rate Time (Derivative).

**#Pb1** (948) or

**Pb1** Proportional Band (Bandwidth). Select 6 to 5000 °F, 3 to 2778 °C, or 6 to 9999 counts.

**Pb2** Proportional Band (Bandwidth). Select 6 to 5000 °F, 3 to 2778 °C, or 6 to 9999 counts. (Appears after #rtE when Option 948 is selected.)

**#rES** (948) or

**rES** Automatic Reset Time. Select **OFF**, 0.1 to 99.9 minutes. Select **OFF** to switch to **OFS**.

**#OFS** (948) or

**OFS** Manual Offset Correction Select **OFF**, 0.1 to 99.9%. Select **OFF** to switch to **rES**.

**#rtE** (948) or

**rtE** Rate Time. Select **OFF**, 0.01 to 99.99 minutes, Derivative.

**SLO** PID values are preset for a slow response process.

**nor** PID values are preset for a normal response process.

**FAST** PID values are preset for a fast response process.

**PId2** Linkage of PID parameters between SP1 and SP2: Select **On** or **OFF**.

**On** Links SP2 to SP1 or #SP1 rEs and rtE terms for heat/cool applications.

**OFF** Sp2 functions without rEs and rtE.

**ArUP** Anti-Reset Wind-up Feature: Select **On** or **OFF**.

**On** When **ArUP** is **On** the accumulated Reset Offset value will be cleared to 0% when the process input is not within the Proportional Band.

**OFF** When **ArUP** is **OFF**, the accumulated Reset Offset Value is retained in memory when the process input is not within the Proportional Band.



**ArtE** Approach Rate Time: Select **OFF**, 0.01 to 99.99 minutes. The function defines the amount of Rate applied when the input is outside of the Proportional Band. The **ArtE** time and the **rtE** time are independent and have no effect on each other. To increase damping effect and reduce overshoot set the approach rate time for a value greater than the natural rise time of the process (natural rise time = process value time to set point).

**PEA** Peak and Valley feature will remember the Highest (**PEA**) and lowest (**VAL**) Input the Instrument has had since the last reset or Power On. At Power On they are reset to the present input, and **VAL** therefore may have to be manually reset. To manually reset the value, **PEA** or **VAL** must be in the lower display and then press the **ENTER** key. This will cause the item to be reset to the present input value.

In the following the symbol "#" will be used following letters to refer to either a number "1" or number "2". The "1" will relate to SP1 functions, the "2" for SP2. If your control is not equipped with a second set point, no SP2 functions will appear. The appearance of **CY#**, **SP#d**, or **PUL#** is dependent upon the output type selected in the Secure Menu item **S#Ot**. If time proportioning (cycle time) was selected, then **CY#** is adjustable. If On - Off was selected, then **SP#d** is adjustable. If pulsed time proportioning was selected then **PUL#** is adjustable. If none of the above are selected the menu indexes directly to **S#Ot**.

**CY#** Cycle Rate: Select 2 to 80 sec. Time Proportioning Control is adjustable in 2 sec. steps. For best contact life, a time should be selected as long as possible without causing the process to wander.

**SP#d** Set Point On-Off Differential. Select 1 to 1999 deg. or counts. When adjusting **SP#d** keep in mind that **SPL** and **SPH** have to be considered to avoid a **CHEC** error message.



**PUL#** Pulsed Time Proportioning Output: Select 1 to 7. 1 = Linear and 7 = most non-linear. Changes output linearly for use in cooling applications or for an extremely fast response processes. At the center of the proportional band, a pulse value of 1 provides an output of one second on and one second off (50% output). A pulse value of 2 provides an output of one second on and two seconds off (33% output). Output at center of band equals one second on, 2<sup>(pulse value - 1)</sup> seconds off.

**S#Ot** Set Point Output Type. FT, Curr, or Volt.

**Ft** refers to Fast Time Proportioning, for Solid State Relay or 5V Logic Outputs. Timing is fixed at 1 sec.

**Curr** refers to Proportional Current Output of 0 to 20 mA.

**Volt** refers to Proportional Voltage Output of 0 to 10 V. Both **Curr** & **Volt** are selected by the Hardware Configuration Code and cannot be changed.

**PctO** Percent Output Feature: Select On or OFF.  
**On** When selected On, the HOME lower display will indicate the output of the controller in percent. An "o" will appear in the right hand side of the lower display to indicate percent output for SP1. An "d" will appear on the right hand corner of the lower display to represent percent output for SP2. The display will alternate between these values.  
**OFF** Percent Output display is disabled.

**Prog** Ramp/Soak Feature: Select On or OFF

**StAt** Status Display in the HOME Position when Prog (above) is On: Select On or OFF. When selected OFF, the HOME display will alternately indicate the normal HOME and the Ramp/Soak partial status in the Lower Display. The partial status display sequences with the set value showing the ramp (S1rA) or soak (S1So) segment being processed at that moment. It will also show the Program output status if at Hold or OoFF.

When selected On, the HOME Display will alternately indicate the normal HOME and the Ramp/Soak full status in both the upper and lower displays. The full status display sequences with the set value; Program run, Hold, or OoFF; and with the time remaining for the ramp S1rA or the soak S1So segments.

**1rt** Ramp Time in Hours & Minutes: Select 0.00 to 99.59 (HH.MM).

**1St** Soak Time in Hours & Minutes: Select 0.00 to 99.59 (HH.MM).

**PEnd** End of Soak action: Select Hold or OoFF.

**Hold** Stay at the Present Set Pt.

**OoFF** Turn Off SP1 and SP2 Outputs at the End of the Soak.

**InPC** Input Correction: Select  $\pm 500$  °F ( $\pm 260$  °C) or  $\pm 1000$  counts. This feature allows the input value to be changed to agree with an external reference or to compensate for sensor error. When setting values having one or more decimal points, the lowest negative value allowed is -199.9, -19.99, or -1.999. **Note:** InPC is reset to zero when the input type is changed, or when decimal position is changed in T/C or RTD ranges. Changing decimal position in current or voltage ranges will not reset InPC.

**FILt** Digital Filter: Select OFF, 1 to 99. In some cases the time constant of the sensor, or noise could cause the display to jump enough to be unreadable. A setting of 2 is usually sufficient to provide enough filtering for most cases, (2 represents approximately a 1 second time constant). When the 0.1 degree resolution is selected this should be increased to 4. If this value is set too high, controllability will suffer.

**LPbr** Loop Break Protection: Select OFF, 1 to 9999 seconds. If, during operation, the output is minimum (0%) or maximum (100%), and the input moves less than 5°F (3°C) or 5 counts over the time set for LPbr, the LOOP bAd message will appear. This condition can also be routed to an Alarm Condition if alarms are present and turned On (see ALbr in the secure menu). The loop break error can be reset by pressing the ENTER key when at the LPbr menu item. The INDEX & ENTER keys may also be used.

**POL** Process Output Low (936): Select -450°F, -260°C, or -1999 counts to 50 degrees or counts less than POH.

**POH** Process Output High (936): Select from 50 degrees or counts greater than POL to +9990°F, +5530°C, or 9990 counts. A voltage output is scalable from 0 to 10 VDC that represents the Process Variable. To properly scale the output, the values for POL and POH must be calculated. The simplest example is an output of 0 to 10 VDC from 0 to 200°. In this example POL=0 and POH=200. To Calculate POL and POH for other ranges use the following:

$$K = \frac{(\text{Highest desired temperature} - \text{Lowest desired temperature})}{(\text{Maximum desired voltage} - \text{Minimum desired voltage})}$$

$$\text{POH} = ((10 - \text{Maximum desired voltage}) * K) + \text{Highest desired temperature}$$

$$\text{POL} = ((\text{Minimum desired voltage} - 0) * K) - \text{Lowest desired temperature}$$

**LOrE** Local / Remote Status (992): Select LOC or rE. When LOC is selected, the host computer is advised not to send remote commands. When rE is selected, CFLt=2, and iAt is set > 0, if the control is not accessed by the host computer in the time set in iAt, the control will revert to the CFSP

**CFSP** Communications Fail Set Point (992): Set to desired value.

**Addr** Control Address (992): Set from 1 to FF. This number (hexadecimal, base 16) must match the address number used by the host computer. Viewed only in this menu.

## SECURE MENU

Hold UP ARROW & ENTER for 5 Seconds. Press INDEX to change the lower display. Press UP ARROW or DOWN ARROW to change the value in the upper display.

**SECr** Security Code: See the Security Level Selection and the Password Table in this manual, in order to enter the correct password.

**InP** Input Type: Select one of the following. The Inputs are based on four different groups; Thermocouples, RTD's, Current, and Voltage. If changing from one of these groups, the DIP switch on the A/D circuit board will have to be changed to match that particular group. Refer to the Input wiring section for the proper switch settings.

J-IC Type "J" Thermocouple, Iron/Constantan (NIST)

CA Type "K" Thermocouple Chromel/Alumel

E- Type "E" Thermocouple Chromel/Constantan

t- Type "T" Thermocouple Copper/Constantan

L- Type "L" Thermocouple Iron/Constantan (DIN)

n- Type "N" Thermocouple Nicrosil/Nisil

r-13 Type "R" Thermocouple Pt 13%Rh/Pt

S-10 Type "S" Thermocouple Pt 10%Rh/Pt

b- Type "B" Thermocouple Pt 6%Rh/Pt 30%Rh

C- Type "C" Thermocouple W 5%Re/W 26%Re

P392 100 ohm Platinum (NIST 0.00392  $\Omega/\Omega/^\circ\text{C}$ ), Love Cal. 104.

n120 120 ohm Nickel, Love Cal. 105.

- P385 100 ohm Platinum (DIN 0.00385  $\Omega/\Omega/^\circ\text{C}$ ), Love Cal. 106.

Curr DC Current Input 0.0 to 20.0 or 4.0 to 20.0 milliamperes.

VolL DC Voltage Input 0.0 to 5.0 or 1.0 to 5.0 volts.

---- Reserved

**OSUP** Zero Suppression: Select On or OFF. Only with Current and Voltage Input types.

**OFF** The input range will start at 0 (zero) input.

**On** The input range will start at 4.00 mA or 1.00 V.

**Unit** F, C or None

**F** °F descriptor is On and temperature inputs will be displayed in actual degrees Fahrenheit.

**C** °C descriptor is On and temperature inputs will be displayed in actual degrees Celsius.

**none** °F and °C descriptors will be Off. This is only available with Current and Voltage Inputs.

**dPt** Decimal Point Positioning: Select 0, 0.0, 0.00, or 0.000. On temperature type inputs this will only effect the Process Value, SP1, SP2, ALLo, ALHi, and InPC. For Current and Voltage Inputs all Menu Items related to the Input will be affected.

**0** No decimal Point is selected. This is available for all Input Types.

**0.0** One decimal place is available for Type J, K, E, T, L, RTD's, Current and Voltage Inputs.

**0.00** Two decimal places is only available for Current and Voltage Inputs.

**0.000** Three decimal places is only available for Current and Voltage Inputs.

**InPt** Input Fault Timer: Select OFF, 0.1 to 540.0 minutes. Whenever an input is out of range, shorted, or open the timer will start. When the time has elapsed, the controller will revert to a safe condition (Outputs Off, Flashing Displays). If OFF is selected, the Input Fault Timer will not be recognized (time = infinite).



**SEnC** Sensor Rate of Change: Select OFF, 1 to 4000 °F, °C, or counts per 1 second period. This value is usually set to be slightly greater than the fastest process response expected during a 1 second period, but measured for at least 2 seconds. If the process is faster than this setting, the SEnC bAd error message will appear. The outputs will then be turned off. This function can be used to detect a runaway condition, or speed up detection of an open thermocouple. Use the INDEX & ENTER keys to reset.

**SCAL** Scale Low: Select 100 to 9999 counts below SCAH. The total span between SCAL and SCAH must be within 11998 counts. Maximum setting range is -1999 to +9999 counts. For Current and Voltage inputs, this will set the low range end. Viewable only for Thermocouples and RTD's.

**SCAH** Scale High: Select 100 to 9999 counts above SCAL. The total span between SCAL and SCAH must be within 11998 counts. Maximum setting range is -1999 to +9999 counts. For Current and Voltage inputs, this will set the high range end. Viewable only for Thermocouples and RTD's.

**SPL** Set Point Low: Select from SCAL value to SPH value. This will set the minimum SP1, SP2, ALLo, ALHi, SP1d, and SP2d values that can be entered. If any of the values are less than the SPL value, a check message will appear and the value will not be accepted.

**SPH** Set Point High: Select from SCAH value to SPL value. This will set the maximum SP1, SP2, ALLo, ALHi, SP1d, and SP2d values that can be entered. If any of the values are greater than the SPH value, a check message will appear and the value will not be accepted.

**SP1o** Set Point 1 Output Terminal Assignment: Select OutA or Outb.  
**NOTE:** Reassigning the output terminals does not change the Hardware type assigned to those terminals. For single set point models, SP1o is locked to OUT A.  
**OutA** Set Pt. 1 output will be directed to terminals 7 & 8 and Set Pt. 2 output to terminals 9 & 10.  
**Outb** Set Pt. 1 output will be directed to terminals 9 & 10 and Set Pt. 2 output to terminals 7 & 8.

**S#Ot** Set Point Output Type: Select CY, OnOF, PUL, or Ft. Fixed for Curr and Volt, the Hardware Configuration has selected this.  
**CY** Cycle Rate, Adjustable Time Proportioning.  
**CY#** Cycle Rate Time: Select 2 to 80 sec.  
**OnOF** On/Off Output.  
**SP#d** Set Point Differential in 1 degree or count steps from 2 degrees or counts to full scale, but limited by SPL and SPH.  
**PUL** Pulse Time Proportioning.  
**PUL#** Pulse Width Value: Select 1 to 7.  
**Ft** Fast Time Proportioning: Fixed at 1 sec. Time Base.  
**Volt** Proportional Voltage, 0 to 10 V.  
**Curr** Proportional Current, 0 to 20 mA.

**S#St** Set Point State: Select dlr or rE.  
**dlr** Direct Action. As the input increases the output will increase. Most commonly used in cooling processes.  
**rE** Reverse Action. As the input increases the output will decrease. Most commonly used in heating processes.

**S#OL** Set Point Output Low Limit: Select 0 to 90% but less than S#OH. This item limits the lowest output value. This is useful for adding a bias to the process when needed. When a current or voltage output is used, the standard output value is 0 to 20mA or 0 to 10V. If 4 to 20 mA or 2 to 10 V is required, the S#OL value should be set for 20% to raise the lowest output.

**S#OH** Set Point Output High Limit: Select 10 to 102% but greater than S#OL. This item allows setting the maximum output limit. This is useful with processes that are over powered.

**S#LP** Set Point Lamp: Select O on or OoFF.  
**O on** Lamp ON when Output is ON.  
**OoFF** Lamp OFF when Output is ON.

**S2t** Set Point 2 type: Select Abs or dE.  
**AbS** Absolute SP2. SP2 is independent of SP1, and may be set anywhere between the limits of SPL and SPH.  
**dE** Deviation SP2. SP2 is set as a deviation from SP1, and allows SP2 to retain its relationship with SP1 when SP1 is changed (tracking SP2).

#### ALARM TYPE AND ACTION (If present)




**Caution:** In any critical application where failure could cause expensive product loss or endanger personal safety, a redundant limit controller is recommended.

When setting an alarm value for an absolute alarm (ALt = AbS), simply set the value at which the alarm is to occur.


When setting the alarm value for a deviation alarm (ALt = dE), set the difference in value from the Set Value (SV) desired. For example if a low alarm is required to be 5 degrees below the SV, then set ALLo to -5. If a high alarm is required 20 degrees above the SV, then set ALHi to +20. If SP1 is changed, the alarm will continue to hold the same relationship as originally set.

The following diagram shows the action and reset functions for both absolute and deviation alarms.

#### ABSOLUTE ALARMS



#### DEVIATION ALARMS



When "Alarm Power Interrupt" ALPi is programmed ON and "Alarm Reset" is programmed for Hold, the alarm will automatically reset upon a power failure and subsequent restoration if no alarm condition is present.

If "Alarm Inhibit" ALIH is selected ON, an alarm condition is suspended upon power up until the process value passes through the alarm set point once. Alarm Inhibit can be restored as if a power up took place by pressing together the INDEX and ENTER keys for 5 seconds.



**Warning:** Resetting a high alarm inhibit will not allow an alarm to occur if the Process Value does not first drop below the high alarm setting. Do not use the Alarm Inhibit feature if a hazard is created by this action. Be sure to test all combinations of high and low alarm inhibit actions before placing control into operation.

The following Secure menu items apply only to the alarm.

- AL** Alarms: Select **OFF**, **Lo**, **HI**, or **HILo**.  
**OFF** Alarms are turned OFF. No Alarm menu items appear in the Secondary and Secure menus.  
**Lo** Low Alarm Only. **ALLo** appears in the Secondary Menu.  
**HI** High Alarm Only. **ALHI** appears in the Secondary Menu.  
**HILo** High and Low Alarms. Both share the same Alarm Relay output.
- ALt** Alarm Type: Select **AbS** or **dE**  
**AbS** Absolute Alarm that may be set anywhere within the values of **SPL** and **SPH** and is independent of **SP1**.  
**dE** Deviation Alarm that may be set as an offset from **SP1**. As **SP1** is changed the Alarm Point will track with **SP1**.
- ALrE** Alarm Reset: Select **OnOF** or **Hold**.  
**OnOF** Automatic Reset.  
**Hold** Manual Reset. Acknowledge by simultaneously pressing the **INDEX & DOWN ARROW** keys for 5 sec.
- ALPI** Alarm Power Interrupt: Select **On** or **OFF**.  
**On** Alarm Power Interrupt is ON.  
**OFF** Alarm Power Interrupt is OFF.
- ALIH** Alarm Inhibit: Select **On** or **OFF**.  
**On** Alarm Inhibit is ON. Alarm action is suspended until the process value first enters a non-alarm condition.  
**OFF** Alarm Inhibit is OFF.
- ALSt** Alarm Output State: Select **CLOS** or **OPEn**.  
**CLOS** Closes Contacts at Alarm Set Point.  
**OPEn** Opens Contacts at Alarm Set Point.
- ALLP** Alarm Lamp: Select **O on** or **OoFF**.  
**O on** Alarm Lamp is ON when alarm contact is closed.  
**OoFF** Alarm Lamp is OFF when alarm contact is closed.
- ALbr** Alarm Loop Break: Select **On** or **OFF**.  
**On** Loop Break Condition will cause an Alarm Condition.  
**OFF** Loop Break will not affect the Alarm Condition.

The following Secure menu items apply only to Options. They may not appear in your control.

- SPSA** Set Point Select Action (948): Select **rE** or **Int**.  
**rE** Remote (external) selection of active set point value.  
**Int** Internal selective of active set point value.
- Addr** Control Address (992): Set from 1 to FF. This number (hexadecimal, base 16) must match the address number used by the host computer.
- bAud** Communications baud rate (992): Select 300, 1200, 2400, 4800, 9600, 19.2, 28.8, or 57.6. This number must match the baud rate used by the host computer. The data format is 8 bits, 1 stop bit, No parity.
- nAt** No Activity Timer (992): Select **OFF** to 99. If a number is set, the control will expect access by the host computer. If no access is detected within that time, the control will indicate an error. **CHEC LoRE** and go to the set point indicated by **CFLt**.
- CFLt** Communication Fault Mode (992): Select 1 or 2. 1 = On Communication fault use local Set Point. 2 = On Communications fault use **CFSP**.

## DIAGNOSTIC ERROR MESSAGES

DISPLAY	MEANING	SP1, SP2, and ALARM OUTPUTS	ACTION REQUIRED
UFL or OFL	Underflow or Overflow: Process value has exceeded input range ends set by SCAL or SCAH.	Set point outputs active Alarms active	Input signals may normally go above or below range ends. If not, check input and correct.
bAd InP  OPEn InP	UFL or OFL will sequence to display one of these messages if the InPt is set for a time value. For RTD, CURRENT, or VOLTAGE inputs; input error has occurred. For THERMOCOUPLE inputs the thermocouple is open.	Set point outputs inactive Alarms active	To reset use the <b>INDEX &amp; ENTER</b> keys. When InPt (input fault timer) has been set for a time, the outputs will be turned off after the set time. Setting the time to OFF causes the outputs to remain active, however UFL or OFL will still be displayed. Correct or replace sensor. To reset use the <b>INDEX &amp; ENTER</b> keys.
LOOP bAd	The sensor may be defective, heater fuse open, heater open or the final power output device is bad.	Set point outputs inactive Alarms active	Correct or replace sensor, or any element in the control loop that may have failed. To reset use the <b>INDEX &amp; ENTER</b> keys, or press the <b>ENTER</b> key while in the <b>LPBr</b> menu item.
SEnC bAd	Sensor rate of change exceeded the programmed limits set for SEnC.	Set point outputs inactive Alarms active	Check the cause. The value setting may be too slow for the process, or the sensor is intermittent. To reset use the <b>INDEX &amp; ENTER</b> keys.
#### ArEA	Area appears if the controller's ambient temperature nears specification ends, -5°C (+23°F) or +50°C (+122°F).	Set point outputs active Alarms active	Correct the ambient temperature conditions. Ventilate the area of the cabinet or check for clogged air filters.
(blank) ArEA	Area appears if the controller's ambient temperature exceeds specification ends, -10°C (+14°F) or +55°C (+131°F).	Set point outputs inactive Alarms active	Correct the ambient temperature conditions. Ventilate the area of the cabinet or check for clogged air filters. To reset use the <b>INDEX &amp; ENTER</b> keys.
CHEC CAL	Check calibration appears as an alternating message if the instrument calibration nears tolerance edges.	Set point outputs active Alarms active	Remove the instrument for service and / or recalibration. To reset use the <b>INDEX &amp; ENTER</b> keys.
	Check calibration appears as a flashing message if the instrument calibration exceeds specification.	Set point outputs inactive Alarms active	



DISPLAY	MEANING	SP1, SP2 AND ALARM OUTPUTS	ACTION REQUIRED
No displays lighted	Both displays are blank. Instrument may not be getting power, or the supply voltage is too low.	Set points inactive Alarms inactive	Check that the power supply is on, or that the external fuses are good.
FAIL TEST	Fail test appears upon power up if the internal diagnostics detect a failure. This message may occur during operation if a failure is detected. Displays flash.	Set points inactive Alarms inactive	Press the INDEX key to display the following messages: FACT dFLt: Memory may be corrupted. Press the ENTER key and the DOWN ARROW key to start the factory default procedure. Re-check controller programming. bAdA-d: The A/D board is bad, return to factory. rEt FACT: Can not recover from error, return to factory for service.
CHEC SCAL or CHEC SCAH	The difference between scale low and scale high is programmed for more than 11,998 or less than 100 counts during programming of the voltage or current ranges.	Set points inactive Alarms inactive	Program parameter within the allowed count range.
CHEC SP1, CHEC #SP1, CHEC SP1d, CHEC SP2, CHEC SP2d, CHEC ALLo, CHEC ALHi, or CHEC CFSP	One or more of these messages will appear upon power up if any of these set points or differentials are set outside of the SPL or SPH values, or the range ends (SCAL or SCAH).	Set points inactive Alarms inactive	Check that each of the set points are within SPL, SPH range, or re-program SPL and / or SPH values to be at or beyond the set points values found in error. Do not exceed the range ends (SCAL or SCAH).
CHEC SPL or CHEC SPH	This message appears at power up if SPL or SPH values are programmed above or below the range ends (SCAL or SCAH). This message also appears if one or more set points are set above or below SPL or SPH during normal programming.	Set points inactive Alarms inactive	Correct the SPL or SPH values by programming new values. CAUTION: The old values are retained when these messages appear during set point programming.
CHEC POL or CHEC POH	This message appears if the POL or POH values are incorrectly programmed.	Set points active Alarms active	Correct the POL or POH by programming new values.

## CONFIGURATION MENU




DO NOT ENTER THE CONFIGURATION MENU UNLESS YOU HAVE BEEN INSTRUCTED TO BY ANOTHER PART OF THESE INSTRUCTIONS. INCORRECT ENTRY OF DATA IN THE CONFIGURATION MENU MAY PREVENT YOUR CONTROL FROM OPERATING PROPERLY.

If re-configuration is required, follow the instructions below.

The Configuration Menu is used to quickly configure the instrument. The configuration for your particular model is shown on the Model / Serial label located on the top of the instrument housing. A label found inside on the right printed circuit board only shows the hardware configuration and options.

The numbers shown are defined as follows:



The Hardware configuration code must not be changed as it defines the hardware for the specific instrument. All other configuration may be altered if necessary. It is important that the codes be correctly entered in order for the instrument to function properly. If an invalid code number is entered for a particular configuration item, it will not be accepted and the old configuration code will be retained.

To re-configure:


1. At power up, simultaneously press and hold the INDEX & ENTER keys while the lamp test or self test is displayed. Hold the keys down until Hrd1 appears. A dash appears in the upper display.
2. Press the INDEX key to advance through the menu items. Pressing the INDEX & DOWN keys simultaneously will back up to a menu item. Stop at the menu item you wish to change.
3. Press the UP or DOWN key to select the desired Configuration Code from the following chart.
4. Press ENTER to retain.
5. Press INDEX to advance.
6. If you do not want to retain the re-configuration, this is your last chance to return to the old configuration. Press ENTER at AcPt no to exit and retain the old configuration.

## CONFIGURATION CHART

Do not change Hrd1, Hrd2 or Hrd3 to codes different from those on the controller labels. Codes in boldface type indicate factory defaults. See FACt dFLt.

DISPLAY	MENU ITEM	CONFIGURATION CODE
Hrd1	Alarm Hardware	0 = NO      1 = YES
Hrd2	Output A Hardware	1 = SSR/LOGIC    3 = RELAY/LOGIC    5 = CURRENT 2 = LOGIC/SSR    4 = LOGIC/RELAY    6 = VOLTAGE
Hrd3	Output B Hardware	0 = NONE      2 = LOGIC/SSR      4 = LOGIC/RELAY 1 = SSR/LOGIC    3 = RELAY/LOGIC
OPt1	Option Hardware	936 = Process Output      948 = 4-Stage Set Point 992 = Serial Communications If number flashes, option is NOT selected. Press ENTER to select (number will not flash).
CnF1	Input Type	01 = J 1°      11 = N 1°      21 = RTD 1° NI 02 = J 0.1°      12 = N 0.1°      22 = RTD 0.1° NI 03 = K 1°      13 = R 1°      23 = 0 to 20 mA 04 = K 0.1°      14 = S 1°      24 = 4 to 20 mA 05 = E 1°      15 = B 1°      25 = 0 to 5 VDC 06 = E 0.1°      16 = C 1°      26 = 1 to 5 VDC 07 = T 1°      17 = RTD 1° (DIN) 08 = T 0.1°      18 = RTD 0.1° (DIN) 09 = L 1°      19 = RTD 1° (NIST) 10 = L 0.1°      20 = RTD 0.1° (NIST)
CnF2	Temperature Descriptor	0 = No Descriptor    2 = Degree C 1 = Degree F
CnF3	SP1 and SP2 Action	0 = SP1 = Output A, rev. act. (Single set point Models) 1 = SP1 = Output A, dir. act. (Single set point Models) 2 = SP1 = Output A, rev. act.; SP2 = Output B, dir. act. 3 = SP1 = Output B, rev. act.; SP2 = Output A, dir. act. 4 = SP1 = Output A, dir. act.; SP2 = Output B, rev. act. 5 = SP1 = Output B, dir. act.; SP2 = Output A, rev. act. 6 = SP1 = Output A, rev. act.; SP2 = Output B, rev. act. 7 = SP1 = Output B, rev. act.; SP2 = Output A, rev. act. 8 = SP1 = Output A, dir. act.; SP2 = Output B, dir. act. 9 = SP1 = Output B, dir. act.; SP2 = Output A, dir. act.
CnF4	Alarm Type	0 = No Alarm      4 = Deviation Low Alarm 1 = Absolute High Alarm    5 = Absolute High - Low Alarms 2 = Deviation High Alarm    6 = Deviation High - Low Alarms 3 = Absolute Low Alarm
CnF5	Alarm Action	0 = No Alarm      4 = On - Off with Inhibit 1 = On - Off      5 = Manual Reset with Inhibit 2 = Manual Reset with Power Interrupt 3 = Manual Reset without Power Interrupt
CnF6	Alarm State	0 = No Alarm      3 = Close at SP, LED off 1 = Close at SP, LED flashing 2 = Open at SP, LED flashing 4 = Open at SP, LED off

## CONFIGURATION CHART, CONT'D.

DISPLAY	MENU ITEM	CONFIGURATION CODE
AcPt	Accept Configuration	no = Retain old Configuration. Press ENTER to exit. YES = Accept Configuration. Press ENTER to exit.
id ##		Factory Identification. Not for customer use.
FACt dFLt		Factory default. Defaults Configuration to factory codes shown in boldface type in the chart above.  <div>  <p><b>Warning:</b> The Hardware Configuration will be cleared and must be re-entered using the Hardware Configuration code found on the Model/Serial label located on the top of the instrument housing. The configuration menu cannot be exited until valid Hardware codes are entered.</p> </div> <p>If factory default is desired, simultaneously press the ENTER &amp; DOWN ARROW keys.</p>

### Input Ranges

#### Thermocouple Types

Input Type		Type J or L Iron- Constantan	Type K Chromel- Alumel	Type E Chromel- Constantan	Type T Copper- Constantan	
Temperature Range & Unit of measure	1°F	-100 to +1600	-200 to +2500	-100 to +1800	-350 to +750	
	1°C	-73 to +871	-129 to +1371	-73 to +982	-212 to +398	
	0.1°F	-100.0 to +990.0	-190.0 to +990.0	-100.0 to +990.0	-190.0 to +750.0	
	0.1°C	-73.0 to +871.0	-129.0 to +990.0	-73.0 to +982.0	-212.0 to +398.0	
		Type R PT 13% RH- PT	Type S PT 10% RH- PT	Type B PT 6% RH- PT 30% RH	Type C W 5% RE- W 26% RE	Type N Ni Cro Si- Ni Si
Temperature Range & Unit of measure	1°F	0 to 3200	0 to 3200	+75 to +3308	0 to 4208	-100 to +2372
	1°C	-17 to +1760	-17 to +1760	+24 to +1820	-17 to +2320	-73 to +1300
	0.1°F	.	.	.	.	-100.0 to +990.0
	0.1°C	.	.	.	.	-73.0 to +990.0

#### RTD Types

		100 Ohm Platinum 0.00385 DIN Curve Love Cal. 106	100 Ohm Platinum 0.00392 NIST Curve Love Cal. 104	120 Ohm Nickel Love Cal. 105
Temperature Range & Unit of measure	1°F 1°C 0.1°F 0.1°C	-328 to +1607 -200 to +875 -190.0 to 990.0 -190.0 to +875.0	-328 to +1607 -200 to +875 -190.0 to 990.0 -190.0 to +875.0	-112 to +608 -80 to +320 -112.0 to +608.0 -80.0 to +320.0

**Current and Voltage Types** 0 to 20 mADC, 4 to 20 mADC, 0 to 5 VDC, or 1 to 5 VDC; scalable from 100 to 11,999 counts with adjustable decimal point placement.



## SPECIFICATIONS

**Selectable Inputs:** Thermocouple, RTD, current or voltage.

**Input Impedance:**

Thermocouple = 3 megohms minimum.  
Current = 249 ohms.

RTD current = 200  $\mu$ A.  
Voltage = 5000 ohms.

**Set Point Range:** Selectable.

**Displays:** Two 4 digit, 7 segment 0.3" high LED's. PV red, SV green.

**Control Action:** Reverse (usually heating), Direct (usually cooling) selectable for single or dual set point models.

**Proportional Band:** 6 to 5000 °F or equivalent °C for temperature inputs. 6 to 9990 counts for current or voltage inputs.

**Reset Time (Integral):** Off or 0.1 to 99.9 minutes.

**Rate Time (Derivative):** Off or 0.01 to 99.99 minutes.

**Cycle Rate:** 2 to 80 seconds.

**Approach Rate:** Off to 99.99 minutes.

**On - Off Differential:** Adjustable 1° F to full scale in 1° steps (equivalent °C), or 1 count to full scale in 1 count steps for current and voltage inputs.

**Alarm On - Off Differential:** 2° F or equivalent in °C, or 2 counts.

**Accuracy:**  $\pm 0.25\%$  of span,  $\pm 1$  least significant digit.

**Resolution:** 1 degree, 0.1 degree, or 1 count.

**Line Voltage Stability:**  $\pm 0.05\%$  over the supply voltage range.

**Temperature Stability:** 4  $\mu$ V/°C (2.3  $\mu$ V/°F) typical, 8  $\mu$ V/°C (4.5  $\mu$ V/°F) maximum.

**Common Mode Rejection:** 140 db minimum at 60 Hz.

**Normal Mode Rejection:** 65 db typical, 60 db at 60 Hz.

**Isolation:** Relay and SSR outputs are isolated. Current, voltage, and logic outputs must not share common grounds with the input.

**Supply Voltage:** 100 to 240 VAC, nom., +10 -15%, 50 to 400 Hz. single phase; 132 to 240 VDC, nom., +10 -20%. This applies to the instrument power only.

**Power Consumption:** 5VA maximum.

**Operating Temperature:** -10 to +55 °C (+14 to 131 °F).

**Storage Temperature:** -40 to +80 °C (-40 to 176 °F).

**Humidity Conditions:** 0 to 90% up to 40 °C non-condensing 10 to 50% at 55 °C non-condensing.

**Memory Backup:** Non-volatile memory. No batteries required.

**Control Output Ratings:**

1. SSR, 3.5 A @ 250 VAC at 25 °C. Derates to 1.25 A @ 55 °C.
2. Relay, Form A contact (SPST), 3 A @ 250 VAC resistive; 1.5 A @ 250 VAC inductive; Pilot Duty Rating: 250 VA, 2 A @ 125 VAC or 1 A @ 250 VAC.
3. Alarm Relay, Form A contact (SPST). Same rating as control relay (2) above.
4. Current (non-isolated), 0 to 20 mA across 600 ohms maximum.
5. Voltage (non-isolated), 0 to 10 VDC across 500 ohms minimum.
6. Logic (non-isolated), 5 VDC @ 25 mA.

**Panel Cutout:** 45 mm x 45 mm (1.775" x 1.775").

**Depth Behind Mounting Surface:** 115.3 mm (4.54").

**Weight:** 227 g (8 oz).

**Agency Approvals:** UL E83725, CSA LR40125.

**Front Panel Rating (for indoor, non-hazardous locations):** Meets UL 2, 3R, 3S, and 12 ratings.

### LIMITED WARRANTY

Love Controls Corporation warrants to the Buyer that any equipment sold will be free from defects in material or workmanship. If, at any time within sixty (60) months after shipment of 1600 Series Controls or within three (3) months after shipment of thermocouples, or other assemblies or parts, the Seller is notified of such defect and the defective item is returned to Seller by Buyer, transportation prepaid, for examination, the Seller will, at his option, either repair or replace the defective items.

This warranty shall be effective only if installation and maintenance is in accordance with Sellers instructions and the defect is not caused by shipping damage, misuse or abuse by the Buyer. There are no other warranties, written, oral, or implied. The liability of the Seller is limited to the repair or replacement of the defective item as above set forth.

Items which wear or are perishable by misuse are not warranted. These include, but are not limited to, relays, contact points, lamps, LED's, load SCR's, SSR's and triacs.